

Report Test No. 8453479

Issue by: BSI Assurance UK Limited, BSI Group

Issue date: 27 July 2016


Standard: BS 5315:1991

OBBSW5

Free-turning torque test


Size	Ø mm.	Std.(max)	Result
000	12	1.500	0.274
1X	40	1.500	0.314
4	90	1.500	0.587
6X	140	1.500	0.284
12	280	1.500	0.316

OBBSW5



Torque Test

Size	Ø mm.	Std.(min)	Result
000	12	4.500	9.860
1X	40	6.800	13.890
4	90	9.000	18.690
6X	140	9.000	15.850
12	280	1.500	1.870



Hydraulic pressure

Size	Ø mm.	Std.(min)	Result
000	12	1.400	>1.4
1X	40	0.700	>0.7
4	90	0.300	>0.3
6X	140	0.300	>0.3
12	280	NA	NA

